

City of Isle of Palms, SC
Request for Bids (RFB 2023-04)
Bark Park Fencing

Addendum # 1 – Answers to Questions

Item #1:

Proper removal and disposal of existing bark park fencing. Replace and install with commercial grade galvanized steel black vinyl coated fencing to existing Bark Park layout. 4-foot fencing approximately 842 feet to include big dog park and small dog park areas. Three (3) 4-foot-wide walk gates, One (1) 10-foot double gate and One (1) 8-foot double gate. All fencing will have bottom tension wire and post must be set in dirt and secured with concrete.

Request: What are the specifications for the fence and material?

Answer: Commercial Grade Vinyl Fencing

Chain Link – 9 gauge
Line Post – 2"
Terminal post – 3"
Top rail – 1 5/8"